




Article number: 00 216 06 99

Exposed shower tap VITUS VD -C-T / u Mixed water, ThermoProtect thermostat

Triggering via CVD-Touch electronics with automatic closing. Battery operation. Shower connection at bottom. Integrated SWS BE-F VITUS wireless bus extender for networking with the SWS water management system. Configurable via SCHELL Single Control SSC.



Scope of delivery

- Electronic self-closing exposed shower tap
 - ThermoProtect thermostat, conform to EN 1111, unlockable/lockable temperature lock at 38 °C, anti-scalding protection if cold water supply fails
 - 6 V solenoid valve with pre-filter
 - CVD-Touch electronics, programmable, IP65 protection against low-pressure water jets
 - SWS BE-F VITUS wireless bus extender
 - 6 V battery compartment (integrated)
- 4x AA alkaline battery 1.5 V
- 2 backflow preventers (EN 1717: EB-type)
- 2 S-connections and rosettes (depth-adjustable)

Technical data

- Setting options via SWS SSC
 - Actuation force (soft/medium/hard)
 - Manual programming (off/on)
 - Max. flow time (1-950 s)
 - Stagnation flush (off/1-1000 s, every 1-250 h after last flush/every 1-250 h)
 - Actuation timeout (off/1-255 s, timeout 1-2000 min)
- Setting options via manual programming
 - Max. flow time (4-120 s, 10 program stages)
 - Stagnation flush (off/20 s, every 24 h)
- Flow pressure: 1.0 - 5.0 bar
- Max. Resting pressure: 8 bar
- Max. operating temperature: 70 °C (80 °C for thermal disinfection)
- Connection: 2x DN 15 G 1/2 AG
- Outlet: DN 15 G 1/2 AG (bottom)
- Material: Housing Brass, conform to German drinking water regulations
- Surface: Chrome
- Certificates: PA-IX 28574/IB, Belgaqua
- Noise class: I
- Flow class: B

Delivery data

- Weight: 4,30 kg/Piece
- Packing unit: 1

Necessary associated articles

SWS Server

Article no: 00 500 00 99

Recommended associated articles

S-connecting with isolating valve	Article no: 23 775 00 99	
Shower set 900	Article no: 29 207 06 99	or
Shower set 680	Article no: 29 208 06 99	or
Flow restrictor LEED	Article no: 29 239 00 99	or
Flow restrictor BREEAM	Article no: 29 240 00 99	or
<u>For parametrisation with Single Control SSC before start-up SWS water management system</u>		
SSC Bluetooth® module	Article no: 00 916 00 99	